



# QUALITY CONTROL DISTRICT LAB KERALA WATER AUTHORITY

VADAVATHOOR, KOTTAYAM

Telephone No. 0481 2302391, Email- qedlkottayam@gmail.com

## TEST REPORT

Report No:672/KTM/07/2022

Date: 26-07-2022

Customer Name & Address THE PRINCIPAL MARY MATHA PUBLIC SCHOOL KADAPLAMATTOM PO KADAPLAMATTOM	1.Date of Receipt	19-07-2022
	2.Sampling done by	CHC KADAPLAMATTOM
	3.Sample Code	2022/QC/KTM/K2337
	4.Source of Sample	Open well
	5.Sample Quantity	100 ml
	6.Test performing dates:22.07.2022- 23.07.2022	

### BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per – IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	IS 15185:2016	Absent
2	E-coli	Shall not be detected/100ml	IS 15185:2016	Absent

Test method


Coliforms: Membrane Filtration Method

E. coli: Membrane Filtration Method

Remarks: -

NB:- The result stated above related only to the sample(s) submitted for testing. This Test Certificate shall not be reproduced except in full without the written approval of the laboratory

- \*Samples will be retained only for 7 days after completion of analysis
- \*Sampling is not done by the Lab



*[Signature]*  
Authorized By

Page 1-1

Rev. Date : 00

KWA/QC/KTM/AR/E4

Issue No.01

Issue Date : 22.10.2021

Rev. No.00

*[Signature]*  
PRINCIPAL  
MARY MATHA PUBLIC SCHOOL  
KADAPLAMATTOM



*[Signature]*  
MANAGER  
MARY MATHA PUBLIC SCHOOL  
CBSE Affn. No. C30845  
KADAPLAMATTOM